



Accepted Utah PSC  
Docket No.: 22-030-04

## ELECTRIC SERVICE REGULATION NO. 8

### VIII - METERING

#### 1. Installation

- a. The member shall make provision for the connection of metering equipment at a convenient place, readily accessible without risk of bodily harm to MLEA employees, free from vibration, corrosive atmosphere, and abnormal temperatures, in which to install MLEA's metering equipment and shall furnish a meter base for MLEA's meter. All meter locations and provisions for connecting metering equipment are subject to approval by MLEA. MLEA will furnish, install and maintain at its own expense the necessary meter or meters and accessories except meter bases, to measure the electric service used by the member. The member shall provide and maintain a satisfactory location for the installation without expense to MLEA. The member will not interfere with, or alter, or permit interference with or alteration of MLEA's meter or other property; including cutting the seals without specific permission from the meter department of MLEA.

#### 2. Failure to Register

- a. If MLEA's meter fails at any time to register accurately, MLEA may estimate the member's power and energy during the time of such failure on the basis of the best available data. If any appliance or wiring connections are found on the member's premises which prevent the meter from accurately recording the total amount of power and energy used on the premises, MLEA may at once remove such wiring or appliances and may estimate the power and the amount of energy consumed and not registered, as accurately as it is able to do so. The member will immediately pay for such estimated power and energy consumption together with the expense of removing any such wiring or appliances and restoring the equipment of MLEA to its normal operating condition. MLEA may also refuse further service or require the member to make such changes in the wiring installation as MLEA deems proper.
- b. Meter Tests and Adjustments. MLEA will test and inspect its meters from time to time and maintain their accuracy of registration in accordance with generally accepted practices and the rules and standards established by the Regulatory Commissions. MLEA will make special tests when requested by the member. If any such special test shows the average registration of a meter to be in error by more than 2% fast or slow, MLEA will bear the cost of the test. If the amount of error is less than 2% the member shall bear the cost of the test unless the meter has not been tested at the member's request within a 12 month period immediately preceding such request. When an average error of more than 2% is determined, MLEA will make a refund where the meter is fast and the member shall pay the difference where the meter is slow. The billing adjustment shall be made according to the provisions of Regulation No. 11, Adjustment of Error.